

TRANE VOY1525 VERTICAL ECONOMIZERS I/O/M MANUAL

Table of Contents

Trane Economizer Description	.3
VOY1525 Vertical Submittal	
VOY1525 Vertical Install	
Additional Install Notes	

For information on iAIRE's Economizer Controls Package, please refer to IOM-0014

Trane Economizer Description

PLEASE NOTE: Our economizer is a low leak, field installed economizer with the iAIRE patented controls packages and actuator, allowing you to reduce the amount of outside air needed from your rooftop HVAC system by up to 2/3 and will improve indoor air quality.

This reduction in system operation creates on-going utility savings. Payback on capital equipment costs with an iAIRE economizer can be realized in fewer than three years. These packages are designed to work directly on existing rooftop HVAC systems.

These economizers are all low leak and meet the IECC 2015 requirement and are Title 24 compliant by meeting section 120.2(i) for the required controls and the efficiency requirements in 140.4(e).

	Unit to RTU Conversion
VOY1525	TCD, TCH, TFD, TFH, YCD, YCH, YFD, YFH 151-300, WCD, WCH, WFD, WFH, WSD, WSH 150, 180 TSD, TSH 180F-300F/180G-300G, THD, YHD, THH, YHH, 150F/150G, GWSD, GWSH 150E-180E, 240E
VOY1525HE	TCD, TCH, TFD, TFH, YCD, Y CH, YFD, YFH 181-301 WCD, WCH, WFD, WFH, WSD, WSH 240 THD, YHD, THH, YHH 180F-300F/180G-300G TZH, TZD, YZH, YZD 150F-210F, 150G-210G, GWSD, GWSH 150E-180E, 240E

Part Number



configuration (2)

0 - NO ECON

C - CONVERTIBLE H - HORIZONTAL

V - VERTICAL

power exhaust (5)

0 - NO POWER EXHAUST A - 208/230V 1Φ FIXED PE

В - 208/230V 3Ф FIXED PE С - 460V 3Ф FIXED PE

actuator (3)

0 - NO ACTUATOR A - 20 IN-LB

B - 62 IN-LB

C - 160 IN-LB

options (6)

0 - NONE

B-HUMIDITY

C - BACNET

D - BLDG PRESSURE*

R - RTU OPEN

U - ULTRA LOW LEAK

Note: By adding option "D" any

iAIRE LLC | 2100 Consulate Drive Suite 102, Orlando, FL 32837

PD 09/25/21 V.01.00

controls (4)


B - IAQ (NO IONIZATION)

0 - ECON ONLY

A - IAQ

D - DCV

VOY1525 Vertical Submittal



Electrical Data

PART#	WEIGHT	PART	AMPS	PART	AMPS	TOTAL
EC-VOY1525-VBA0-*	410 lbs.	ACTUATOR	.29A	CONTROLS	.27A	.56A

*OPTIONS
0 - No Options
B - Humidity/Enthalpic
C - BACNet

Features

- · iAIRE Patented Controls Scheme Included
- · Low Leak Damper Included
- · VOC, CO2 and Ionization included
- · Heavy Gauge Galvanized Steel Construction
- · American Sterling Grey Paint Finish
- · One Piece Assembly
- · Gear Driven Dampers
- · Uses HVAC Unit Filter Access Door
- · Capable of Relieving up to 100% of the Outside Air Intake

Economizers with Indoor Air Quality control are Title 24 compliant by meeting section 120.2(i) for the required controls and the efficiency requirements in 140.4(e). They also meet California ozone emissions requirements to be CARB certified.

iAIRE, LLC | 2100 Consulate Drive, Suite 102, Orlando, FL 32837 www.myultrapure.com | Toll Free 844-348-9168

PD 09/15/2021 - v 1.00


VOY1525 - Vertical Install


DOWN DISCHARGE ECONOMIZER INSTALLATION INSTRUCTIONS

- 1 REMOVE RETURN AIR COMPARTMENT PANEL FROM BACK OF HVAC UNIT. (SEE DETAIL #1)
- 2 REMOVE SCREWS ON BACK OF HVAC UNIT HOLDING TOP OF HVAC UNIT DOWN. ALSO REMOVE SCREWS ABOUT HALF-WAY DOWN BOTH SIDES OF HVAC UNIT TOP. (SEE DETAIL #1)
- 3 LIFT TOP OF THE HVAC UNIT AND PROP UP WITH SUPPORTS, 2" SPACING REQUIRED. (SEE DETAIL #2)
- 4 WHEN USING THE BELIMO ACTUATOR OPTION, CONSULT CONTROLS CONTRACTOR REGARDING THE ECONOMIZER WIRING REQUIREMENTS.
- 5 SLIDE ECONOMIZER ASSEMBLY INTO THE HVAC UNIT. MAKE SURE THE LEFT AND RIGHT SIDE FLANGES OF THE ECONOMIZER SLIDE INTO THE SIDE GROVES OF THE HVAC UNIT.

 (SEE DETAIL DRAWING #2 & #3)
- 6 REMOVE SUPPORTS USED TO PROP THE TOP OF THE HVAC UNIT. SUPPORTS USED FROM STEP #3.

 NOTE: THE TOP OF HVAC UNIT HOOKS OVER THE TOP FLANGE OF ECONOMIZER (SEE DETAIL #4)
- 7 SECURE TOP OF THE ECONOMIZER
 TO THE HVAC UNIT BY USING SCREWS
 REMOVED IN STEP #2. ALSO SCREW
 ALONG THE SIDE FLANGES OF THE
 ECONOMIZER USING #12 X 1 SCREWS
 PROVIDED WITH ECONOMIZER PACKAGE.
 (SEE DETAIL #5)





VOY1525 - Vertical Install (cont'd)

DOWN DISCHARGE ECONOMIZER INSTALLATION INSTRUCTIONS

- 8 REPLACE ALL SCREWS ALONG THE SIDES OF THE TOP OF THE HVAC UNIT, REMOVED IN STEP #2. (SEE DETAIL #5)
- 9 REMOVE RETURN AIR COMPARTMENT PANEL LOCATED ON THE RIGHT SIDE OF HVAC UNIT.

(SEE DETAIL #6)

JADE MIXED AIR

SENSOR

Manager Land

ELLINING PROPERTY OF THE PROPE

DETAIL #11


TANDARD MIXED AIR SENSOR \(\sigma\)

10 - PLUG ECONOMIZER HARNESS INTO THE HVAC UNIT ECONOMIZER HARNESS.
NOTE: HARNESS WILL BE INSIDE UPPER CORNER OF RETURN AIR COMPARTMENT.
(SEE DETAIL #7)

11 - REMOVE THE DISCHARGE AIR SENSOR FROM THE SHIPPING LOCATION BEHIND THE WATER ENTRAINMENT FILTER ON THE ECONOMIZER AND MOUNT IT IN THE HVAC UNIT SUPPLY FAN COMPARTMENT NEXT TO THE FAN INLET.

HVAC UNIT

SUPPLY BLOWER



Trane Economizer Install Notes

Additional Notes

- 1. Power Supply. Provide disconnect means and overload protection as required.
- 2. Motor Spring-Returns closed when unit is not running.
- 3. Ensure that equipment transformer is sized to handle the extra load of the economizer and actuator.
- 4. When using a heat with defrost feedback, add an isolation relay between O and C. (Field provided and installed).